

STM-S-12-F868

Code: E85SC3. DESCATALOGADO

- > Communications: LoRa-868 MHz.
- > Digital inputs: 3
- > Measure: 45 A
- > Power supply (Vac): 24 Vdc
- > Mounting: DIN rail

Application

Supervision of photovoltaic strings in solar farms and self-consumption installations

Circutor



Analyser for photovoltaic strings

Code: E85SC3.

Specifications

| DC power supply | |
|--|-------------------------------|
| Installation category | CAT II 1500 V |
| Consumption | 3.6 W |
| Nominal voltage | 24 Vdc ± 10 % |
| Mechanical characteristics | |
| Size (mm) width x height x depth | 362 x 114 x 58 (mm) |
| Envelope | Self-extinguishing VO plastic |
| Fastening | DIN rail |
| Weight (kg) | 0,535 |
| Environmental characteristics | |
| Protection class | IP 00 |
| Relative humidity (without condensation) | 5 95 % |
| Installation, location, position. | 3000 m |
| Storage temperature | -25+80 °C |
| Working temperature | -25+70 °C |
| Current measurement circuit | |
| Installation category | CAT II 1500 V |
| Consumption | 1 Chanel: 1.0125 W |
| Impedance | 0.5 mΩ |
| Phase current measuring range | 0.1 45 A DC |
| Minimum current measurement | 0.1 A |
| Voltage measurement circuit | |
| Installation category | CAT II 1500 V |
| Input impedance | 2400 kΩ |
| Voltage measuring range | -251500 Vdc |
| Maximum input voltage consumption | 0,625 mA |
| Minimum measurement voltage (Vstart) | -25 V |
| Input | |
| Accuracy | ± 3°C |
| Range | -30 100°C |
| Resolution | ±0,1 mA |
| Туре | Pt100/1000 |





Analyser for photovoltaic strings

Code: E85SC3.

| Standards | |
|--|---|
| Electrical safety, Maximum height (m) | 3000 |
| Electrical safety, Installation category | Protection against electric shock: Double class II insulation |
| Standards | EN 61000-6-2, EN 61000-6-4, EN 61010-1, EN 61010-2-30 |
| User interface | |
| LED | 4 |
| Digital inputs | |
| Input/output insulation | Optoisolated |
| Quantity | 3 |
| Туре | Potential free contact |
| Maximum short-circuit current | 3.2 mA |
| Maximum open circuit voltage | 24 V |

The minimum configuration of the STM solution is made up of an STM-C module and an STM-S module $% \mathcal{M} = \mathcal{M} = \mathcal{M} + \mathcal{M} +$

Circutor



Analyser for photovoltaic strings

Code: E85SC3.

Dimensions

Connections

×

×

