



CVE-A-AP, Transducer Vac.

Code: M25021. DESCATALOGADO

> Output type: 1

> Analog output: 0...20mA > Measure: 230 Vac > Paramètre: V ~

#### Description

The CVE-A and CVE-AP transducers, convert A.C voltage to D.C process indicator signal.

The analog output is directly proportional to the input signal, calibrated as a RMS with sinus signal of 50Hz.







Narrow section AC Voltage transducer

Code: M25021.

### Specifications

AC power supply	
Nominal voltage	05, 10 Vcc
Mechanical characteristics	
Size (mm) width x height x depth	20 x 70 x 110 (mm)
Weight (kg)	0,054
Environmental characteristics	
Protection class	IP 20 (Terminals) IP 40 (case)
Storage temperature	-40+70 °C
Working temperature	-10+60 °C
Voltage measurement circuit	
Consumption	2,5 VA
Frequency measuring range	45/65 Hz
Voltage measuring range	70110 % Vn
Nominal voltage	0660 V
Maximum permanent measurement voltage	120 % Vn
Standards	
Electrical safety, Maximum height (m)	2000
Standards	IEC 529, IEC 688, IEC 801, EN 50081-1, EN 50082-1, IEC 1010
Analogue inputs	
Load impedance in current	< 500 Ω
Ripple (effective RMS value)	< 2 %
Load impedance in voltage	> 500 Ω
Response time	< 300 ms (099 % Vn)
Analogue outputs	
Current mode, nominal range	010, 20 mAac
Voltage mode: nominal output range	05, 10 Vac
Measurement accuracy	
Phase current measurement	0,5 % FS

#### $\mathsf{CVE}$

Narrow section AC Voltage transducer







Narrow section AC Voltage transducer

Code: M25021.

CODE	TYPE	Output type	Analog output	System	Measure	Paramètre		
AC Voltage transducer								
M25011.	CVE-A	2	420mA	-	300 Vac	V ~		

Specify ACCORDING TO THE CODE TABLE: 1. Code / 2. Input range / 3. Output range / 4. Auxiliary power supply / 5. Specify the network voltage for CFE-AP. xxx-AP types external auxiliary supply not required. 4...20 mA output not not sible

possible.
For other values, see coding table on following pages



Page 3 of 4





Narrow section AC Voltage transducer

Code: M25021.



