



## CV-A Out2

CV-A Out2, Transducer Vac.

Code: M25032.

- > Output type: 2
- > Analog output: 4...20mA
- > Measure: 300 Vac
- > Paramètre: V ~

## Description

The **CV-A** transducers, convert A.C voltage to D.C process indicator signal.

The analog output is directly proportional to the input signal, calibrated as a RMS with sinus signal of 50 Hz.



# CV-A Out2

A.C. Voltage transducer

Code: M25032.

## Specifications

### AC power supply, insulation

|                   |                     |
|-------------------|---------------------|
| Pulse test (kV)   | 4 kV (1,2 / 50µs)   |
| Test voltage (kV) | 3 kV RMS 50 Hz 1min |

### AC power supply

|                 |            |
|-----------------|------------|
| Consumption     | 2,5 VA     |
| Frequency       | 40...90 Hz |
| Nominal voltage | 230 Vca    |

### DC power supply, insulation

|                   |                     |
|-------------------|---------------------|
| Pulse test (kV)   | 3 kV (1,2 / 50µs)   |
| Test voltage (kV) | 2 kV RMS 50Hz 1 min |

### DC power supply

|                 |                           |
|-----------------|---------------------------|
| Consumption     | 2,5 VA                    |
| Nominal voltage | 9...36 Vdc / 90...140 Vdc |

### Mechanical characteristics

|                                  |                    |
|----------------------------------|--------------------|
| Size (mm) width x height x depth | 40 x 72 x 110 (mm) |
| Weight (kg)                      | 0,95               |

### Environmental characteristics

|                     |                                |
|---------------------|--------------------------------|
| Protection class    | IP 20 (Terminals) IP 40 (case) |
| Storage temperature | -40....+70 °C                  |
| Working temperature | -10...+55 °C                   |

### Voltage measurement circuit

|                                       |              |
|---------------------------------------|--------------|
| Input impedance                       | 3000 Ω/V     |
| Frequency measuring range             | 45...65 Hz   |
| Voltage measuring range               | 0...150 % Vn |
| Nominal voltage                       | 0...660 Vca  |
| Maximum permanent measurement voltage | 1000 V       |

### Standards

|                                       |                                     |
|---------------------------------------|-------------------------------------|
| Electrical safety, Maximum height (m) | 2000                                |
| Standards                             | IEC 529, IEC 688, IEC 801, IEC 1010 |

### Analogue inputs

|                           |         |
|---------------------------|---------|
| Load impedance in current | < 500 Ω |
|---------------------------|---------|



# CV-A Out2

A.C. Voltage transducer

Code: M25032.

|                              |                        |
|------------------------------|------------------------|
| Ripple (effective RMS value) | < 0,5 %                |
| Load impedance in voltage    | > 500 Ω                |
| Response time                | < 300 ms (0...99 % Vn) |

## Analogue outputs

|                                    |                                  |
|------------------------------------|----------------------------------|
| Current mode, nominal range        | 4...20 mA                        |
| Displaced output                   | 0,2...2 V / 2...10 V / 4...20 mA |
| Voltage mode: nominal output range | 0...5, 10 Vac                    |

## Measurement accuracy

|                           |          |
|---------------------------|----------|
| Phase current measurement | 0,2 % FS |
|---------------------------|----------|

CV-A  
AC Transducer Voltage

| CODE  | TYPE          | Output type | Analog output | Measure | Paramètre |
|---|---------------|-------------|---------------|---------|-----------|
| AC Voltage. Accuracy: ± 0,2 % reading, 40...90 Hz |               |             |               |         |           |
| M25041.   | CV-A-AP Out1  | 1           | 0...20mA      | 300 Vac | V ~       |
| M25031.   | CV-A Out1     | 1           | 0...20mA      | 300 Vac | V ~       |
| M25032.   | CV-A Out2     | 2           | 4...20mA      | 300 Vac | V ~       |
| M25051.   | CV-A-RMS Out1 | 1           | 0...20mA      | 300 Vac | V ~       |
| M25052.   | CV-A-RMS Out2 | 2           | 4...20mA      | 300 Vac | V ~       |

-AP type: Accuracy: ± 0,5 % reading, 40...90 Hz. External auxiliary supply not required. Specify: Zero value, full scale and output type.  
For other values, see coding table on following pages



# CV-A Out2

A.C. Voltage transducer

Code: M25032.

## Dimensions



## Connections

