

TE-5/0.1

TE-5/0.1, Impedance Transformer

Code: M70911.

> Class 1 Power (VA): 15

> Relation: 5 /0,1 A

Description

- Accuracy class 1
- Power 15 V·A

Application

For applications where the measurement unit can not be installed near the measurement transformer and, as a consequence, the distance between both is longer. The problem lies in the fact that increasing the distance increases the number of losses caused by the overheating of the cable and in some cases the unit might not take readings accurately. With this unit at the transformer's output and another unit at the input of the measurement device we can increase the distance between both without so many power losses.

Creation date: 30/10/2026 - CIRCUTOR, SAU reserves the right to make technical changes or modify the content/images of this document without prior notice, in order to improve its reliability, functionality, design or for other reasons.
It accepts no liability for any errors, inaccuracies or possible lack of information in this document.



TE-5/0.1

Impendace elevator transformer

Code: M70911.

Specifications

Mechanical characteristics

Weight (kg)	0,51

TE
Impedance step-up transformer

CODE	TYPE	Class 1 Power (VA)
M70911.	TE-5/0.1	15

It is used when the distance between the measuring equipment and the current transformer is very long. Two TE must be used, one next to the current transformer and the other next to the measuring equipment.

Creation date: 30/10/2026 - CIRCUTOR, SAU reserves the right to make technical changes or modify the content/images of this document without prior notice, in order to improve its reliability, functionality, design or for other reasons.
It accepts no liability for any errors, inaccuracies or possible lack of information in this document.