



QNA600, Advanced power quality analyzers

Code: Q22010.

> Protocol: HTTPS - NTP - SFTP - IEC61850

> Memory: 16 GB

> Events / Waveform: Yes

> Web server: Yes

> Certification: IEC 61000-4-30 (Class A)

> Energy accuracy: 0,5s

> Communications: Ethernet | Wi-Fi | 4G

> Harmonics: 64

> Class: A

> Measurement Range (V): 11 ... 500 V \sim (V F-N / V Ph-N)

> Measurement Range (A): 0.05 ... 10 A

> Power supply: 180 ... 300 V ~

> Input current: ... / 5 A

> Mounting: Rack

Description

The QNA 600 is a high-end power quality analyzer that measures and records electrical parameters, power quality events and transient events in an electrical installation with maximum accuracy. This allows any incidents that said power quality events may have caused in the installation or on the devices connected to it to be analysed after the fact.

It complies with IEC 61000-4-30, edition 3, and IEC 62586-2. Its designation, PQI-A-FI1-H, defines it as a Class A device for fixed installation in 19" 4U racks, suitable for interiors with uncontrolled temperatures and noisy environments. It has 5 voltage and 5 current measurement channels, and is compatible with current transformers of up to 5 amperes.

The device has two Ethernet ports (front/rear), a simple API and protocols such as IEC 61850, MQTT, ftp and sftp for integration into SCADA applications, as well as to access instantaneous values and historical data, which can be downloaded in PQDIFF and COMTRADE formats.

It generates EN 50160 reports in PDF format automatically, and sends them to sftp or ftp repositories, providing the user with detailed information on the power quality. GPS synchronization ensures the accuracy of the time mark and location.

It also has an internal memory that records data for 5 years and can store up to 4,000 quality events, in standard configuration, for subsequent analysis.

Application

The QNA 600 has been specially designed to be installed at utility demarcation points (transformer station) or at the main connection of any user's electrical installation, operating in parallel to the billing meter. This gives it the ability to automatically detect and analyse the utility's compliance with the EN 50160 standard, and it can also be used to identify power quality events that may cause damage, deterioration or malfunction in the installation loads.

This information allows the user to understand the effects of the problem and to take corrective measures if the quality problems are caused by the loads in the installation itself. Moreover, if the problems are caused by external factors, this device is IEC 61000-4-30 certified, and offers reliable data to demonstrate any incident or damage caused by the utility company.







Power quality analyzer (PQI-A-FI1-H)

Code: Q22010.

Specifications

Auxiliary battery power supply	
Autonomy	30 minutes
Battery type	Ni-MH
Capacity	2500 mAh
AC power supply	
Installation category	CAT III 300 V
Consumption	15 25 VA
Frequency	50 60 Hz.
Nominal voltage	180 300 V ~
Mechanical characteristics	
Size (mm) width x height x depth	210 x 132.25 x 305.2 (mm)
Envelope	Zinc plated sheet steel
Fastening	Rack 19''
Weight (kg)	3,4
Environmental characteristics	
Protection class	IP 20IK 08
Relative humidity (without condensation)	0 95%
Storage temperature	-40+70 °C
Working temperature	-10+45 °C
Current measurement circuit	
Sampling frequency	512 samples / cycle
Nominal current (In)	/5 A
Phase current measuring range	0.05 10 A~
Voltage measurement circuit	
Installation category	CAT IV 600 V
Input impedance	1 ΜΩ
Frequency measuring range	42.5 69 Hz
Voltage measuring range	11 500V Ph-N / 17 866V Ph-Ph
Nominal voltage	230 V ~
Minimum measurement voltage (Vstart)	11 V ~
Communication Network	
Connection mechanism	RJ-45
Protocol	HTTPS-NTP-SFTP-IEC61850







Power quality analyzer (PQI-A-FI1-H)

Code: Q22010.

Electrical safety, Maximum height (m) 2000	Technology / Interface	Ethernet 10 Base T - 100 Base Tx self-detectable
Electrical safety, Installation category	Standards	
	Electrical safety, Maximum height (m)	2000
	Electrical safety, Installation category	CAT IV (600 V) o CAT III (1000 V) IEC 61010
Double-insulated electric shock protection class II (IEC 61010-1)	Standards	61010-1, IEC 60297-3-100, IEC 62053-22, IEC-62053-23, IEC 17065, IEC 61850,
LED	Electrical safety	
Resolution of the display	Insulation	Double-insulated electric shock protection class II (IEC 61010-1)
Resolution of the display 240 x 128 points Keyboard 7 keys Measurement accuracy Current unbalance (Kd) ± 0,15 % (IECG1000-4-30 class A) Voltage unbalance (Kd) ± 0,15 % (IECG1000-4-30 class A) Frequency measurement ± 0,1 % (IEC-61557-12 class 0.1) Phase current measurement ± 0,2 % (IEC-61557-12 class 0.2) (0.5 10 A-)]± 0.2% (IEC 61000-4-30, class A) (10 120% 6157) Reactive energy measurement (kwarh) ± 1 % (IEC-62053-24 class 1s) Reactive power measurement (kwar) ± 1 % (IEC-61557-12 class 0.5) Active energy measurement (kWh) ± 0,5 % (IEC-61557-12 class 0.5) Power factor measurement (kW) ± 0,5 % (IEC-61557-12 class 0.5) Current THD (10 100%)-Class 1 (IEC 61000-4-7)Class A (IEC 61000-4-30) Voltage THD (10 100%)-Class 1 (IEC 61000-4-7)Class A (IEC 61000-4-30) Phase voltage measurement ± 0,1 % (IEC-61557-12 class 0.1) (50 500 V-)]± 0.1% Un (IEC 61000-4-30, class A) (10 150% Un) Phist Flicker Class F1 (IEC 61000-4-715)class A (IEC 61000-4-30) Redic communication ± 0,5 % (IEC 615000-4-15)class A (IEC 61000-4-30)	User interface	
Resourcement accuracy Current unbalance (Kd) ± 0.15 % (IEC61000-4-30 class A) Voltage unbalance (Kd) ± 0.15 % (IEC61000-4-30 class A) Frequency measurement ± 0.1% (IEC-61557-12 class 0.1) Phase current measurement ± 0.2 % (IEC-61557-12 class 0.2) (0.5 10 A-) ± 0.2% (IEC 61000-4-30, class A) (10 120% FS) Reactive energy measurement (kvarh) ± 1 % (IEC-62053-24 class 1s) Reactive power measurement (kWh) ± 0.5 % (IEC-61557-12 class 0.5) Active energy measurement (kWh) ± 0.5 % (IEC-61557-12 class 0.5) Active power measurement (kW) ± 0.5 % (IEC-61557-12 class 0.5) Power factor measurement ± 0.5 % (IEC-61557-12 class 0.5) Current THD (10 100%):Class I (IEC 61000-4-7) class A (IEC 61000-4-30) Voltage THD (10 100%):Class I (IEC 61000-4-7) class A (IEC 61000-4-30) Phase voltage measurement ± 0.1 % (IEC-61557-12 class 0.1) (50 500 V-)]± 0.1% Un (IEC 61000-4-30, class A) (10 150% Un) Neutral voltage measurement ± 0.1 % (IEC 61000-4-15) class A (IEC 61000-4-30) Radio communication 24 6Hz, IEEE 802.11 b / g / n	LED	6 LED
Measurement accuracy Current unbalance (Kd) ± 0,15 % (IEC61000-4-30 class A) Voltage unbalance (Kd) ± 0,15 % (IEC61000-4-30 class A) Frequency measurement ± 0,1 % (IEC-61557-12 class 0.1) Phase current measurement ± 0,2 % (IEC.61557-12 class 0.2) (0.5 10 A))± 0.2% (IEC 61000-4-30, class A) (10 120% FS) Reactive energy measurement (kvarh) ± 1 % (IEC.62053-24 class 1s) Reactive power measurement (kwh) ± 0,5 % (IEC.62053-22 class 0.5) Active energy measurement (kWh) ± 0,5 % (IEC.61557-12 class 0.5) Active power measurement ± 0,5 % (IEC.61557-12 class 0.5) Power factor measurement ± 0,5 % (IEC.61557-12 class 0.5) Current THD (10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30) Voltage THD (10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30) Phase voltage measurement ± 0,1 % (IEC.61557-12 class 0.1) (50 500 V))± 0.1% Un (IEC 61000-4-30, class A) (10 1500 W un) Neutral voltage measurement ± 0,1 % (IEC.61557-12 class 0.1) (50 500 V))± 0.1% Un (IEC 61000-4-30, class A) (10 1500 W un) Pinst. Flicker Class F1 (IEC 61000-4-15)Class A (IEC 61000-4-30)	Resolution of the display	240 x 128 points
Current unbalance (Kd) ± 0,15 % (IEC61000-4-30 class A) Voltage unbalance (Kd) ± 0,15 % (IEC61000-4-30 class A) Frequency measurement ± 0,1 % (IEC-61557-12 class 0.1) Phase current measurement ± 0,2 % (IEC.61557-12 class 0.2) (0.5 10 A-) ± 0.2% (IEC 61000-4-30, class A) (10 120% FS) Reactive energy measurement (kvarh) ± 1 % (IEC 62053-24 class 1s) Reactive power measurement (kvar) ± 1 % (IEC 61557-12 class 1) Active energy measurement (kWh) ± 0,5 % (IEC 62053-22 class 0.5s) Active power measurement (kW) ± 0,5 % (IEC 61557-12 class 0.5) Power factor measurement ± 0,5 % (IEC 61557-12 class 0.5) Current THD (10 100%):Class 1 (IEC 61000-4-7)Class A (IEC 61000-4-30) Voltage THD (10 100%):Class 1 (IEC 61000-4-7)Class A (IEC 61000-4-30) Phase voltage measurement ± 0,1 % (IEC-61557-12 class 0.1) (50 500 V-)]± 0.1% Un (IEC 61000-4-30, class A) (10 150% Un) Neutral voltage measurement ± 1% FS (2 150 V) Pinst. Flicker Class F1 (IEC 61000-4-15)Class A (IEC 61000-4-30) Radio communication ± (IEC 61000-4-15)Class A (IEC 61000-4-30) Feeb communication ± (IEC 61000-4-15)Class A (IEC 61000-4-15)Class A) (IEC 61000-4-15)Class A) (IEC 61000-4-15)Class A)	Keyboard	7 keys
Voltage unbalance (Kd)	Measurement accuracy	
## Securior measurement ## 10,1 % (IEC-61557-12 class 0.1) Phase current measurement ## 10,2 % (IEC-61557-12 class 0.2) (0.5 10 A-)] ± 0.2% (IEC 61000-4-30, class A) (10 120% FS) Reactive energy measurement (kvarh) ## 11 % (IEC-62053-24 class 1s) Reactive power measurement (kwar) ## 11 % (IEC-62053-22 class 1) Active energy measurement (kWh) ## 0,5 % (IEC-62053-22 class 0.5s) Active power measurement (kW) ## 0,5 % (IEC-61557-12 class 0.5) Power factor measurement ## 0,0 % (IEC-61557-12 class 0.5) Current THD ## 100%: Class 1 (IEC 61000-4-7) Class A (IEC 61000-4-30) Voltage THD ## 100%: Class 1 (IEC 61000-4-7) Class A (IEC 61000-4-30) Phase voltage measurement ## 20,1 % (IEC-61557-12 class 0.1) (50 500 V-)] ± 0.1% Un (IEC 61000-4-30, class A) (10 150% Un) Neutral voltage measurement ## 1% FS (2 150 V) Pinst. Flicker ## Class F1 (IEC 61000-4-15) Class A (IEC 61000-4-30) Radio communication Technology / Type ## 46 Wireless communication Band ## 2.4 GHz, IEEE 802.11 b / g / n	Current unbalance (Kd)	± 0,15 % (IEC61000-4-30 class A)
Phase current measurement ± 0,2 % (IEC-61557-12 class 0.2) (0.5 10 A-) ± 0.2% (IEC 61000-4-30, class A) (10 120% FS) Reactive energy measurement (kvarh) ±1 % (IEC-62053-24 class 1s) Reactive power measurement (kvar) ± 1 % (IEC 61557-12 class 1) Active energy measurement (kWh) ± 0,5 % (IEC-62053-22 class 0.5s) Active power measurement (kW) ± 0,5 % (IEC-61557-12 class 0.5) Power factor measurement ± 0,5 % (IEC-61557-12 class 0.5) Current THD (10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30) Voltage THD (10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30) Phase voltage measurement ± 0,1 % (IEC-61557-12 class 0.1) (50 500 V-)]± 0.1% Un (IEC 61000-4-30, class A) (10 150% Un) Neutral voltage measurement ±1% FS (2 150 V) Pinst. Flicker Class F1 (IEC 61000-4-15)Class A (IEC 61000-4-30) Radio communication Wireless communication Band 2.4 GHz, IEEE 802.11 b / g / n	Voltage unbalance (Kd)	± 0,15 % (IEC61000-4-30 class A)
(10 120% FS) Reactive energy measurement (kvarh)	Frequency measurement	± 0,1 % (IEC-61557-12 class 0.1)
Eactive power measurement (kvar)	Phase current measurement	
Active energy measurement (kWh)	Reactive energy measurement (kvarh)	±1 % (IEC-62053-24 class 1s)
Active power measurement (kW)	Reactive power measurement (kvar)	± 1 % (IEC 61557-12 class 1)
Power factor measurement ± 0,5 % (IEC-61557-12 class 0.5) Current THD (10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30) Voltage THD (10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30) Phase voltage measurement ± 0,1 % (IEC-61557-12 class 0.1) (50 500 V~) ± 0.1% Un (IEC 61000-4-30, class A) (10 150% Un) Neutral voltage measurement ±1% FS (2 150 V) Pinst. Flicker Class F1 (IEC 61000-4-15)Class A (IEC 61000-4-30) Radio communication Technology / Type 4G Wireless communication Band 2.4 GHz, IEEE 802.11 b / g / n	Active energy measurement (kWh)	± 0,5 % (IEC-62053-22 class 0.5s)
Current THD (10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30) Voltage THD (10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30) Phase voltage measurement ± 0,1 % (IEC-61557-12 class 0.1) (50 500 V-) ± 0.1% Un (IEC 61000-4-30, class A) (10 150% Un) Neutral voltage measurement ±1% FS (2 150 V) Pinst. Flicker Class F1 (IEC 61000-4-15)Class A (IEC 61000-4-30) Radio communication Technology / Type 4G Wireless communication Band 2.4 GHz, IEEE 802.11 b / g / n	Active power measurement (kW)	± 0,5 % (IEC-61557-12 class 0.5)
Voltage THD (10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30) Phase voltage measurement ± 0,1 % (IEC-61557-12 class 0.1) (50 500 V~) ± 0.1% Un (IEC 61000-4-30, class A) (10 150% Un) Neutral voltage measurement ±1% FS (2 150 V) Pinst. Flicker Class F1 (IEC 61000-4-15)Class A (IEC 61000-4-30) Radio communication Technology / Type 4G Wireless communication Band 2.4 GHz, IEEE 802.11 b / g / n	Power factor measurement	± 0,5 % (IEC-61557-12 class 0.5)
Phase voltage measurement ± 0,1 % (IEC-61557-12 class 0.1) (50 500 V~) ± 0.1% Un (IEC 61000-4-30, class A) (10 150% Un) Neutral voltage measurement ±1% FS (2 150 V) Pinst. Flicker Class F1 (IEC 61000-4-15)Class A (IEC 61000-4-30) Radio communication Technology / Type 4G Wireless communication Band 2.4 GHz, IEEE 802.11 b / g / n	Current THD	(10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30)
A) (10 150% Un) Neutral voltage measurement ±1% FS (2 150 V) Pinst. Flicker Class F1 (IEC 61000-4-15)Class A (IEC 61000-4-30) Radio communication Technology / Type 4G Wireless communication Band 2.4 GHz, IEEE 802.11 b / g / n	Voltage THD	(10 100%):Class I (IEC 61000-4-7)Class A (IEC 61000-4-30)
Pinst. Flicker Class F1 (IEC 61000-4-15)Class A (IEC 61000-4-30) Radio communication Technology / Type 4G Wireless communication Band 2.4 GHz, IEEE 802.11 b / g / n	Phase voltage measurement	
Radio communication Technology / Type 4G Wireless communication Band 2.4 GHz, IEEE 802.11 b / g / n	Neutral voltage measurement	±1% FS (2 150 V)
Technology / Type 4G Wireless communication 2.4 GHz, IEEE 802.11 b / g / n	Pinst. Flicker	Class F1 (IEC 61000-4-15)Class A (IEC 61000-4-30)
Wireless communication Band 2.4 GHz, IEEE 802.11 b / g / n	Radio communication	
Band 2.4 GHz, IEEE 802.11 b / g / n	Technology / Type	4G
·	Wireless communication	
Technology / Type Wi-Fi	Band	2.4 GHz, IEEE 802.11 b / g / n
	Technology / Type	Wi-Fi







Power quality analyzer (PQI-A-FI1-H)

Code: Q22010.

QNA 600

Advanced power quality analyzers (according Standard UNE-EN-50160 and IEC 61000-4-30)

CODE	TYPE Measurement Range (V)	Energy accuracy	Measurement Range (A)	Communications	Protocol	Certification	Memory
022010	ONA 600 11 500 V ~ (V F-N / V Ph-N	N 5s	0.05 10 A	Ethernet Wi-Fi 4G	HTTPS - NTP - SETP - IEC61850	IFC 61000-4-30 (Class A)	16 GB








Power quality analyzer (PQI-A-FI1-H)

Code: Q22010.

Dimensions Connections

QNA600

Soporte de Rack / Rack support



RED trifásica - 3 hilos 3-wire three-phase mains

