



T-SABT-BRIDGE, Bridge card for backup line,

Code: Q32400.

#### Description

T-SABT is the analyser that allows the three-phase voltage and current of a line to be measured to transmit the data, using RS-485, to the R-SABT advanced low-voltage monitor. The device can be installed on the sensor (CAP), located at the output of the low-voltage switchboard in the transformer substation, or in a specially designed cabinet.







Advanced low-voltage monitoring card

Code: Q32400.

#### **Specifications**

CAT IV 300 V
0.1 W
24 V
93 x 59 x 50 (mm)
V0 self-extinguishing plastic
0,3
IP 2XB
5 95 %
-25 +70 °C
-10 +70 °C
CAT IV 300V
> 300 kΩ
127/220 230/400 V ~ ± 20 %
0.03 VA
20 V ~
2000
CAT IV 300 V
UNE-EN 61010-1, UNE-EN 61000-6-2, UNE-EN 61000-6-4
4 indication LED

#### T-SABT

Advanced Low-voltage Monitoring Cards

CODE	TYPE	Description
Advanced Low-v	oltage Monitoring Cards	
Q32000.	T-SABT	Advanced low voltage monitoring card
Q32400.	T-SABT-BRIDGE	Bridge card for backup line



Page 2 of 4





Advanced low-voltage monitoring card

Code: Q32400.

CODE	TYPE	Description
Q32002.	T-SABT FLEX	Advanced low voltage monitoring card, Rogowski assembly
Advanced Monit	oring Accessories	
Q32200.	VTN	Neutral to earth voltage monitor
Q32103.	EXT-NEUTRO	









Advanced low-voltage monitoring card

Code: Q32400.

## **Dimensions**

# Connections





