



410-QT7B-A0B10, Three-phase energy meter indirect connection

Code: QBN3B

> Communications: RS-232 | Ethernet > Class (Active/Reactive): B (1) / 2

> System: Three-phase > Measure: Indirect

> Measurement Range (V): 3x230/400 > Measurement Range (A): .../ 1

> Quadrants: 4 > Frequency (Hz): 60

Description

CIRWATT-B410T is an indirect multi-rate three-phase meter and logger, Class B in active energy as per the European MID Directive (EN 50470), or Class 1 as per IEC-62053-21 and Class 2 reactive energy as per IEC-62053-23, with multiple communications options and expansion modules that allow it to be adapted to any type of industrial and tertiary sector installation.

Application

CIRWATT B-410T is perfect for low- and medium-voltage supplies using external current transformers. Offering solutions for a wide variety of installations such as: shopping centres, industries and highconsumption residential areas (Consumer type 3). Available in 2 quadrants for energy consumption or 4 quadrants for photovoltaic plants (energy generation and consumption).







Indirect multi-rate three-phase meter and logger, Class B in active energy as per the European MID Directive (EN 50470), or Class 1 as per IEC-62053-21

Code: QBN3B

Specifications

Tolerance	80 % 115 % Un
Consumption	< 2 W; < 10 VA
Frequency	50 / 60 Hz
Nominal voltage	3 x 230 (400) V
lattery specification	
Performance-guarantee	> 20 years @ 30 °C
Туре	Lithium
Mechanical characteristics	
Size (mm) width x height x depth	172 x 255 x 67 (mm)
Envelope	DIN 43859
Weight (kg)	0,67
invironmental characteristics	
Relative humidity (without condensation)	95 % max.
Storage temperature	-40 +85 °C
Working temperature	-40 +70 °C
oltage measurement circuit	
Connection	Asymmetrical
Consumption	< 2 W; 10 VA
Nominal frequency	50 / 60 Hz
Nominal voltage	3x230/400 V
urrent measurement circuit	
Consumption	< 0,1 V·A
Reference current (Iref)	/ 5 A
Maximum current	10 A
Minimum current measurement	< 0,5 x ltr
ommunication Network	
Protocol	REE, basado en IEC 870-5-102
Technology / Type	Ethernet







Indirect multi-rate three-phase meter and logger, Class B in active energy as per the European MID Directive (EN 50470), or Class 1 as per IEC-62053-21

Code: QBN3B

Hardware	IEC 62056-21
Protocol	REE, based on IEC 870-5-146
Туре	Serial;bi-directional
User interface	
Resolution of the display	up to 8 digits (8 mm)
Display type	LCD
Memory	
Memory capacity	Data: non-volatile memory, Setup and events: serial-flash
Write time	4000
Туре	Serial flash
Standards	
Standards	UNE-EN 50470-1 Electricity metering equipment (a.c.) Part 1: General requirements, tests and test conditions - Metering equipment -class indexes B-) UNE-EN 50470-3 Electricity metering equipment (a.c.) Part 3: Particular requirements - Static meters for active energy -class indexes B-) IEC 62052-11, IEC 62053-21, IEC 62053-22 (Standards for static active energy meters for alternating current of class 0.2s, 0.5s) UNE-EN 55022 (Conducted Emissions: Class B, Radiated Emissions: Class B) UNE-EN 61000-4-2, UNE-EN 61000-4-3, UNE-EN 61000-4-4, UNE-EN 61000-4-5, UNE-EN 61000-4-6, UNE-EN 61000-4-8, UNE-EN 61000-4-11
PLC	
Hardware	CENELEC A or CENELEC B
Protocol	CirPLC & PEP (PLC Encapsulated Protocol)
Modulation system	DSCK with repeater system
Measurement accuracy	
Reactive energy measurement (kvarh)	IEC 62053-23 (Class 2)
Active energy measurement (kWh)	EN 50470 (Class B) IEC 62053-21 (Class 1)
Features / performance	
Billing closures	12 locks per contract. Programable date and hour
Load curve	2 load curves, programmable integration time (1 253 min)
Optional	Communications: RS-232 / PLC, RS-485 / PLC, RS-232 / RS-232 , RS-485 / RS-485, RS-232 / RS-485, RS-232 / Ethernet, R-485 / Ethernet. Expansion boards: No inputs / outputs, 4 relay outputs (Rate Indicator), 2 relay inputs / 4 pulse outputs, 4 pulse inputs, Differential current measurement, 2 relay outputs / 2 pulse outputs, / 2 pulse inputs
Tariff programming	12 days 10 types of data 9 types of tariffs 30 public holidays 12 special days







Indirect multi-rate three-phase meter and logger, Class B in active energy as per the European MID Directive (EN 50470), or Class 1 as per IEC-62053-21

Code: QBN3B

Clock

Source	Temperature compensated oscillator
Accuracy (EN 61038)	< 0,5 s/day (23 °C)
Туре	Gregorian calendar
Serial communication	

Serial communication

Protocol	REE, basado en IEC 870-5-102
Technology / Type	RS-232

CIRWATT B 410T

Indirect multi-rate three-phase meter and logger, Class B in active energy as per the European MID Directive (EN 50470), or Class 1 as per IEC-62053-21

CODE	TYPE	Measurement Range (V)	Measurement	Communications	Class	System	Measure
	ITPE	Measurement Range (V)	Range (A)	Communications	(Active/Reactive)	System	Measure
CIRWATT B	410T						
QB860	410-QT5A-70B10	3x230/400	/5	RS-232 RS-232	B (1) / 2	Three-phase	Indirect
CIRWATT B	505						
QBN40	410-VT7B-A0B10	3x57/100 3x230/400	/ 1	RS-232 Ethernet	C (0,5S)/1	Three-phase	Indirect
CIRWATT B	410T						
QB8A0	410-QT5A-80B10	3x230/400	/5	RS-485 RS-485	B (1) / 2	Three-phase	Indirect
QB870	410-QT5A-90B10	3x230/400	/5	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QB870T21	410-QT5A-90B10-TRMC210-100-3.0.TD	3x230/400	/5	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QB870T22	410-QT5A-90B10-TRMC210-200-3.0.TD	3x230/400	/5	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QB870T23	410-QT5A-90B10-TRMC210-500-3.0.TD	3x230/400	/5	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QB880	410-QT5A-A0B10	3x230/400	/5	RS-232 Ethernet	B (1) / 2	Three-phase	Indirect
QB890	410-QT5A-C0B10	3x230/400	/5	RS-485 Ethernet	B (1) / 2	Three-phase	Indirect
QBJ10	410-VT5A-90B10	3x57/100 3x230/400	/5	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QBG60	410-NT5A-70B10	3x127/220	/5	RS-232 RS-232	B (1) / 2	Three-phase	Indirect
QBJ20	410-VT5A-A0B10	3x57/100 3x230/400	/5	RS-232 Ethernet	B (1) / 2	Three-phase	Indirect
QBG70	410-NT5A-90B10	3x127/220	/5	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QB8D0	410-QT5B-90B10	3x230/400	/5	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QBGA0	410-NT5A-80B10	3x127/220	/5	RS-485 RS-485	B (1) / 2	Three-phase	Indirect
QBG80	410-NT5A-A0B10	3x127/220	/5	RS-232 Ethernet	B (1) / 2	Three-phase	Indirect
QB8E0	410-QT5B-A0B10	3x230/400	/5	RS-232 Ethernet	B (1) / 2	Three-phase	Indirect
QBG90	410-NT5A-C0B10	3x127/220	/5	RS-485 Ethernet	B (1) / 2	Three-phase	Indirect
QBJ60	410-VT5B-90B10	3x57/100 3x230/400	/5	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QBH20	410-MT5A-70B10	3x63,5/110	/5	RS-232 RS-232	B (1) / 2	Three-phase	Indirect
QBJ70	410-VT5B-A0B10	3x57/100 3x230/400	/5	RS-232 Ethernet	B (1) / 2	Three-phase	Indirect
QBH30	410-MT5A-90B10	3x63,5/110	/5	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QBNOB	410-QT7A-90B10	3x230/400	/ 1	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QBH61	410-MT5A-80B10	3x63,5/110	/5	RS-485 RS-485	B (1) / 2	Three-phase	Indirect
QBH40	410-MT5A-A0B10	3x63,5/110	/5	RS-232 Ethernet	B (1) / 2	Three-phase	Indirect
QBN1B	410-QT7A-A0B10	3x230/400	/ 1	RS-232 Ethernet	B (1) / 2	Three-phase	Indirect







Indirect multi-rate three-phase meter and logger, Class B in active energy as per the European MID Directive (EN 50470), or Class 1 as per IEC-62053-21

Code: QBN3B

CODE	TYPE	Measurement Range (V)	Measurement Range (A)	Communications	Class (Active/Reactive)	System	Measure
QBH50	410-MT5A-C0B10	3x63,5/110	/5	RS-485 Ethernet	B (1) / 2	Three-phase	Indirect
QBNOJ	410-VT7A-90B10	3x57/100 3x230/400	/ 1	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QBN1J	410-VT7A-A0B10	3x57/100 3x230/400	/ 1	RS-232 Ethernet	B (1) / 2	Three-phase	Indirect
QBN2B	410-QT7B-90B10	3x230/400	/ 1	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QBN3B	410-QT7B-A0B10	3x230/400	/ 1	RS-232 Ethernet	B (1) / 2	Three-phase	Indirect
QBN2J	410-VT7B-90B10	3x57/100 3x230/400	/ 1	RS-232 RS-485	B (1) / 2	Three-phase	Indirect
QBN3J	410-VT7B-A0B10	3x57/100 3x230/400	/ 1	RS-232 Ethernet	B (1) / 2	Three-phase	Indirect
				· · · · · · · · · · · · · · · · · · ·	* *		

Please contact us for other configurations (Inputs, outputs and other communications)







Indirect multi-rate three-phase meter and logger, Class B in active energy as per the European MID Directive (EN 50470), or Class 1 as per IEC-62053-21

Code: QBN3B

Dimensions Connections





