



CMFR3-066-120

Code: R9CMFR.

La description

The capacitor banks must be equipped with detuned filters when there is a high level of harmonics. In this case, CIRCUTOR recommends the use of automatic **CMFR** or **CMAR** capacitor banks, equipped with iron core REACTORS and synchronised capacitors, up to 7% of the insulation voltages of 7.2 kV. For higher voltage levels, air core technology is used in these REACTOR

Application

The most common applications are: Medium Voltage industrial networks

- o Compensation of large motors. Usually 3 to 11 kV
- o Compensation of HV / MV transformers
- Fixed or automatic compensation of the following installations: cement plants, pumping stations, pipelines, mining, paper industry.

Generation and distribution systems

- o Receiving and distributing stations. Particularly indoor installations, where the use of space is vital
- Generation stations that need an automatic power factor regulation: small-scale hydraulic power plants, wind farms, etc







CMFR3-066-120

Fixed or automatic capacitor banks in cabinet with detuned filter

Code: R9CMFR.

Spécifications

Caractéristiques électriques	
Fréquence	50 / 60 Hz
Niveau d'isolation	7,2 33 kV
Puissance	600 7200 kvar
Tension	7,2 33 kV
Caractéristiques mécaniques	
Matériel	Panneaux et cadres : acier peint et traité
Caractéristiques environnementales	
Installation, lieu, position.	Intérieur / Extérieur

CIRKAP-CMFR / CMAR

Batteries de condensateurs MT fixes ou automatiques en armoire avec filtres désaccordés

CODE	TYPE
R9CMFR.	CMFR3-066-120

